

# Energy Audit: A Case Study Of Electrical Machines Lab

Rishikesh.G, Harish Kumar.M.N, Gokulakrishnan.G, Praveenkumar.M

**Abstract:** The increase in machines lab all over Indian Engineering college's energy consumption has been more apparent than such increases in the industrial and transportation sectors. The main objective of this project is to analysis the energy consumption of the machine's lab in VIT. On an periodical monitoring of these energy meter daily at a particular time for one month we can able to find the power factor, active, reactive and apparent powers of that particular lab. Thus, we can able to give solutions on what basis the load can be decreased. What amount of capacitor should be placed in order to maintain the power factor and reactive power. Thus, by plotting the graph and comparing all the outputs of the above-mentioned monitoring process the total amount is calculated according to TNEB norms can also be calculated. And after placing the capacitor the amount in reduction of cost can also be calculated.

## 1. INTRODUCTION

Vitality is one of the significant contributions for the monetary advancement of any nation. On account of the creating nations, the vitality division expect a basic significance in perspective on the regularly expanding vitality needs requiring colossal ventures to meet them. For lessening cost and expanding productivity, at that point use vitality preservation, the executives and review. The target of Energy Management is to accomplish and keep up ideal vitality obtainment what's more, usage, all through the association as to limit vitality costs/squander without influencing creation and quality. To limit natural impacts. Vitality Audit is the way to a precise methodology for basic leadership in the territory of vitality the executives. It endeavors to adjust the all outvitality contributions with its utilization, and serves to recognize all the vitality streams in an office.

## 2. PRINCIPLE

At the point when the object of study is an involved structure at that point decreasing vitality utilization while keeping up or improving human solace, wellbeing and security are of essential concern. Past essentially distinguishing the wellsprings of vitality use, a vitality review looks to organize the vitality utilizes as indicated by the best to least savvy open doors for vitality investment funds.

## 3. METHODOLOGY

The readings had been taken manually will the machines in the lab is running (Fig1). We have taken the readings from the control panel of that particular lab which is shown in Fig2. We have calculated the reactive power of the total lab on a daily basis. Based on that the Capacitance required of a individual day is calculated.

For a set of five days we have calculated the mean Capacitance KVAR that needs to be implemented in the lab so has to reduce the reactive power for a certain extent. Has the reactive power of the lab is reduced so that the electricity bill of our institute with respect to that of a particular lab has been reduced. The maximum demand of the lab has also been calculated from the electrical blueprint of the lab. The readings taken on different days has been shown in Table 1, Table 2, Table 3, Table 4 and Table 5.



*Fig1. VIT Machines Lab*



*Fig.2 ControlPannel*

- Rishikesh.G, Harish Kumar.M.N, Gokulakrishnan.G, Praveenkumar.M
- School of Electrical Engineering, Vellore Institute of Technology, Vellore-632 014, India [rishikesh.g2016@vitstudent.ac.in](mailto:rishikesh.g2016@vitstudent.ac.in), [harishkumar.mn2016@vitstudent.ac.in](mailto:harishkumar.mn2016@vitstudent.ac.in), [gokul.g@vit.ac.in](mailto:gokul.g@vit.ac.in), [praveen.m@vit.ac.in](mailto:praveen.m@vit.ac.in)
- School of Electrical Engineering, Vellore Institute of Technology, Vellore-632 014, India

## 4. TYPES OF ENERGY AUDIT

The term vitality review is usually used to portray an expansive range of vitality ponders running from a speedy stroll through of an office to recognize serious issue territories to a far reaching examination of the ramifications of elective vitality effectiveness estimates adequate to fulfill the money related criteria of modern financial specialists. Various review

methodology have been produced for non-private (tertiary) structures Audit is required to recognize the most proficient and financially savvy Energy Conservation Opportunities (ECOs) or Measures (ECMs). Vitality protection openings (or measures) can comprise in increasingly proficient use or of incomplete or worldwide substitution of the current establishment. When looking to the current review techniques created in IEA, by ASHRAE and by Krarti (2000), it gives the idea that the fundamental issues of a review procedure are:

- The examination of structure and utility information, including investigation of the introduced hardware and investigation of vitality bills;
- The review of the genuine working conditions;
- The comprehension of the structure conduct and of the connections with climate, inhabitation and working timetables;
- The choice and the assessment of vitality protection measures;
- The estimation of vitality sparing potential;
- The distinguishing proof of client concerns and needs.

Regular sorts/dimensions of vitality reviews are recognized underneath, despite the fact that the genuine assignments performed and dimension of exertion may change with the expert giving administrations under these expansive headings. The best way to guarantee that a proposed review will meet your particular needs is to explain those necessities in a point by point extent of work. Setting aside the effort to set up a formal sale will likewise guarantee the structure proprietor of getting focused and equivalent proposition. For the most part, four dimensions of examination can be plot (ASHRAE):

- Level 0 – Benchmarking: This first examination comprises in a starter Whole Building Energy Use (WBEU) investigation dependent on the investigation of the memorable utility use and costs and the correlation of the exhibitions of the structures to those of comparable structures. This benchmarking of the contemplated establishment permits deciding whether further examination is required;
- Level I – Walk-through review: Preliminary examination made to survey building vitality productivity to recognize straightforward and minimal effort upgrades as well as a rundown of vitality preservation measures (ECMs, or vitality protection openings, ECOs) to situate the future point by point review. This investigation depends on visual checks, investigation of introduced gear and working information and point by point examination of recorded vitality utilization gathered amid the benchmarking stage;
- Level II – Detailed/General vitality review: Based on the aftereffects of the pre-review, this sort of vitality review comprises in vitality use overview so as to give an extensive examination of the contemplated establishment, a progressively nitty gritty investigation of the office, a breakdown of the vitality use and a first

quantitative assessment of the ECOs/ECMs chose to address the imperfections or improve the current establishment. This dimension of examination can include progressed nearby estimations and refined PC based reproduction devices to assess exactly the chose vitality retrofits;

- Level III – Investment-Grade review: Detailed Analysis of Capital-Intensive Modifications concentrating on potential expensive ECOs requiring thorough building study.

## 5. BENCHMARKING

The inconceivability of portraying every single imaginable circumstance that may be experienced amid a review implies that it is important to discover a method for depicting what comprises great, normal and terrible vitality execution over a scope of circumstances. The point of benchmarking is to respond to this inquiry. Benchmarking essentially comprises in contrasting the deliberate utilization and reference utilization of other comparative structures or produced by reenactment devices to recognize extreme or unsuitable running expenses. As referenced previously, benchmarking is additionally important to recognize structures exhibiting intriguing vitality sparing potential. A critical issue in benchmarking is the utilization of execution files to describe the structure. These lists can be:

- Comfort lists, contrasting the real solace conditions with the solace necessities;
- Energy records, comprising in vitality requests isolated by warmed/molded region, permitting examination with reference estimations of the files originating from guideline or comparable structures;
- Energy requests, legitimately contrasted with "reference" vitality requests produced by methods for recreation devices.

Commonly, benchmarks are set up dependent on the vitality outlets (loads) inside the structure and are then additionally parsed into "base loads" and "climate touchy burdens". These are built up through a straightforward relapse investigation of vitality utilization and request (whenever metered) corresponded to climate (temperature and degree - day) information amid the period for which utility information is accessible. Total base burdens will speak to as the capture of this relapse and the slant will commonly speak to the mix of structure envelope conduction and invasion misfortunes less misfortunes or additions from the base burdens themselves. For instance, while lighting is normally a base burden, the warmth produced from that lighting must be subtracted from the climate touchy cooling load got from the slant to pick up a precise image of the genuine commitment of the structure envelope on cooling vitality use and request.

## 6. WALK-THROUGH (OR) PRELIMINARY AUDIT

The primer review (on the other hand called a basic review, screening review or stroll through review) is the least complex and fastest kind of review. It includes negligible meetings with site-working faculty, a short survey of office service bills and other working information, and a stroll through of the office to get comfortable with the structure activity and to distinguish

any glaring zones of vitality waste or wastefulness. Normally, just serious issue regions will be secured amid this kind of review. Remedial measures are quickly portrayed, and speedy appraisals of usage cost, potential working cost reserve funds, and basic compensation periods are given. A rundown of vitality protection measures (ECMs, or vitality preservation openings, ECOs) requiring further thought is likewise given. This dimension of detail, while not adequate for achieving an official conclusion on actualizing proposed measure, is satisfactory to organize vitality effectiveness ventures and to decide the requirement for a progressively point by point review.

## 7. GENERAL AUDIT

The general review (on the other hand called a smaller than expected review, site vitality review or point by point vitality review or complete site vitality review) develops the starter review depicted above by gathering increasingly nitty gritty data about office activity and by playing out a progressively itemized assessment of vitality preservation measures. Service bills are gathered for a 12-to three-year time frame to enable the reviewer to assess the office's vitality request rate structures and vitality use profiles. In the event that interim meter information is accessible, the nitty gritty vitality profiles that such information influences conceivable will to ordinarily be dissected for indications of vitality squander. Extra metering of explicit vitality devouring frameworks is frequently performed to enhance utility information. Top to bottom meetings with office working faculty are led to give a superior comprehension of real vitality devouring frameworks and to pick up knowledge into short-and longer-term vitality utilization designs. This sort of review will almost certainly distinguish all vitality preservation estimates proper for the office, given its working parameters. A point by point money related examination is performed for each measure dependent on nitty gritty execution cost gauges, site-explicit working cost funds, and the client's venture criteria. Adequate detail is given to legitimize venture execution. The development of cloud-based vitality reviewing programming stages is empowering the directors of business structures to work together with general and forte exchanges contractual workers in performing general and vitality framework explicit reviews. The advantage of programming empowered joint effort is the capacity to distinguish the full scope of vitality effectiveness choices that might be pertinent to the particular structure under examination with "live time" cost and advantage gauges provided by neighborhood temporary workers.

## 8. INVESTMENT-GRADE AUDIT

In most corporate settings, moves up to an office's vitality framework must vie for capital financing with non-vitality related speculations. Both vitality and non-vitality ventures are evaluated on a solitary arrangement of money related criteria that for the most part stress the normal degree of profitability (ROI). The anticipated working investment funds from the execution of vitality ventures must be grown with the end goal that they give an abnormal state of certainty. Truth be told, financial specialists frequently request ensured funds. The speculation grade review develops the nitty gritty review depicted above and depends on a total designing investigation so as to detail specialized and financial issues important to legitimize the venture identified with the changes.

## 9. SIMULATION-BASED ENERGY AUDIT PROCEDURE FOR NON-RESIDENTIAL BUILDINGS


A total review method, fundamentally the same as the ones proposed by ASHRAE and Krarti (2000), has been proposed in the edge of the AUDITAC and HARMONAC ventures to help in the execution of the EPB ("Energy Performance of Buildings") order in Europe and to fit to the present European market. The accompanying system proposes to make a concentrated utilization of current BES apparatuses at each progression of the review procedure, from benchmarking to definite review and monetary investigation:

- Benchmarking stage: While standardization is required to permit examination between information recorded on the contemplated establishment and reference esteems found from contextual analyses or insights. The utilization of reenactment models, to play out a code-agreeable recreation of the establishment under examination, permits to survey straightforwardly the considered establishment, with no standardization required. To be sure, applying a recreation-based benchmarking instrument permits an individual standardization and permits maintaining a strategic distance from size and atmosphere standardization.
- Preliminary review organizes: Global month to month utilizations are commonly lacking to permit an exact comprehension of the structure's conduct. Regardless of whether the investigation of the vitality bills does not permit relating to exactness the diverse vitality customers present in the office, the utilization records can be utilized to align building and framework reproduction models. To survey the current framework and to recreate effectively the structure's warm conduct, the reenactment show must be aligned on the contemplated establishment. The emphases expected to play out the alignment of the model can likewise be completely coordinated in the review procedure and help in distinguishing required estimations and basic issues.
- Detailed review arranges: At this stage, nearby estimations, sub-metering and observing information are utilized to refine the adjustment of the BES device. Broad consideration is given to comprehension not just the working qualities of all vitality devouring frameworks, yet additionally circumstances that reason load profile minor departure from short-and longer-term bases (for example every day, week after week, month to month, yearly). At the point when the alignment criteria is fulfilled, the reserve funds identified with the chose ECOs/ECMs can be measured.
- Investment-grade review arrange: At this stage, the outcomes given by the adjusted BES apparatus can be utilized to evaluate the chose ECOs/ECMs and situate the point by point building study.

**TABLE 1 READINGS TAKEN ON 29.08.2018**

| Time(am)                                     | Voltage(V) | Current(A) | Power Factor | $\phi$      | $\sin\phi$   | Active Power(KW) | Reactive Power(KVAR) |
|--|------------|------------|--------------|-------------|--------------|------------------|----------------------|
| 10.38  | 407.4      | 4.208      | 0.492        | 60.52787923 | -0.743051672 | 843.4548864      | -1273.842608         |
| 10.39  | 407.5      | 6.056      | 0.598        | 53.27320792 | 0.133467727  | 1475.75636       | 329.3743265          |
| 10.40  | 406        | 4.986      | 0.614        | 52.12070561 | 0.959822648  | 1242.930024      | 1942.984344          |
| 10.41  | 405.9      | 6.163      | 0.64         | 50.2081805  | -0.057270604 | 1600.999488      | -143.2659483         |
| 10.42  | 405.1      | 6.716      | 0.688        | 46.52800069 | 0.561244852  | 1871.808301      | 1526.951706          |
| 10.43  | 407.7      | 6.836      | 0.688        | 46.52800069 | 0.561244852  | 1917.481594      | 1564.210282          |
| 10.44  | 406.5      | 5.381      | 0.637        | 50.43152093 | 0.165276615  | 1393.358831      | 361.5221842          |
| 10.45  | 405.3      | 5.477      | 0.641        | 50.13357254 | -0.131527705 | 1422.909812      | -291.9688965         |
| 10.46  | 404.3      | 6.716      | 0.681        | 47.07816392 | 0.045709949  | 1849.104863      | 124.1152542          |
| 10.47  | 404.5      | 9.562      | 0.64         | 50.2081805  | -0.057270604 | 2475.41056       | -221.5129011         |
| 10.48  | 403.4      | 8.363      | 0.62         | 51.68386553 | 0.988407566  | 2091.653204      | 3334.525569          |
| 10.49  | 403.7      | 3.997      | 0.445        | 63.57666123 | 0.67783078   | 718.0470605      | 1093.740223          |
| 10.50  | 404        | 4.188      | 0.518        | 58.80180918 | 0.776096006  | 876.431136       | 1313.11719           |
| 10.51  | 402.9      | 7.839      | 0.666        | 48.24091153 | -0.898798871 | 2103.44945       | -2838.706225         |
| 10.52  | 402.4      | 12.73      | 0.758        | 40.71180186 | 0.128545959  | 3882.894416      | 658.4833574          |
| 10.53  | 402.8      | 5.172      | 0.394        | 66.79637879 | -0.733143682 | 820.8129504      | -1527.344743         |
| <b>Mean Power Factor</b>                     |            |            | 0.6075       |             |              |                  |                      |
| <b>Energy Meter Readings: 144 to 145.1Wh</b> |            |            |              |             |              |                  |                      |
| Time   |            | 0.25 hours |              |             |              |                  |                      |
| Kw   |            | 4.4        |              |             |              |                  |                      |
| Angle  |            | 52.591     |              |             |              |                  |                      |
| Kvar   |            | 5.7531     |              |             |              |                  |                      |
| Improved Angle(PF=0.9)                       |            | 25.8419    |              |             |              |                  |                      |
| Improved Kvar                                |            | 2.131      |              |             |              |                  |                      |
| Capacitor Ratings Should be                  |            | 3.6221     |              |             |              |                  |                      |

**GRAPH 2**




**GRAPH 2 shows the relation between the Load Distribution in KW and KVAR which is taken on a mentioned date of 29.08.2018**

**TABLE 2 READINGS TAKEN ON 30.08.2018**

| Time(am)                                       | Voltage(V) | Current(A) | Power Factor | $\phi$      | $\sin\phi$   | Active Power(KW) | Reactive Power(Kvar) |
|--|------------|------------|--------------|-------------|--------------|------------------|----------------------|
| 10.17  | 413.50     | 3.133      | 0.446        | 63.51266376 | 0.629423185  | 577.960993       | 815.419023           |
| 10.18  | 412.80     | 3.133      | 0.44         | 63.89611886 | 0.874432965  | 569.053056       | 1130.906252          |
| 10.19  | 413.30     | 1.987      | 0.22         | 77.29096701 | 0.948621161  | 180.669962       | 779.0334046          |
| 10.20  | 412.50     | 2.969      | 0.442        | 63.76844121 | 0.805541129  | 541.322925       | 986.5562899          |
| 10.21  | 412.30     | 3.77       | 0.528        | 58.12957778 | 0.999948857  | 820.707888       | 1554.291505          |
| 10.22  | 412.00     | 3.821      | 0.54         | 57.31636115 | 0.694477448  | 850.099608       | 1093.282511          |
| 10.23  | 411.00     | 4.662      | 0.51         | 59.33617026 | 0.346737114  | 977.20182        | 664.3767424          |
| 10.24  | 411.60     | 4.634      | 0.506        | 59.60224289 | 0.08790393   | 965.1213264      | 167.6639479          |
| 10.25  | 412.70     | 4          | 0.546        | 56.90697335 | 0.350687929  | 901.3368         | 578.9156324          |
| 10.26  | 412.10     | 4.22       | 0.563        | 55.73647731 | -0.725795751 | 979.091906       | -1262.203811         |
| 10.27  | 410.40     | 5.178      | 0.57         | 55.24977425 | -0.963261613 | 1211.279184      | -2046.980247         |
| 10.28  | 410.20     | 5.841      | 0.565        | 55.59770869 | -0.813973008 | 1353.727683      | -1950.261582         |
| 10.30  | 410.70     | 3.483      | 0.516        | 58.93568017 | 0.684982914  | 738.1215396      | 979.8462072          |
| 10.31  | 410.20     | 3.907      | 0.542        | 57.18010843 | 0.590308243  | 868.6370588      | 946.0583317          |
| 10.32  | 410.50     | 3.65       | 0.516        | 58.93568017 | 0.684982914  | 773.1357         | 1026.327024          |
| 10.33  | 411.30     | 4.624      | 0.592        | 53.70093691 | -0.289650632 | 1125.89591       | -550.8724023         |
| 10.34  | 412.60     | 3.078      | 0.44         | 63.89611886 | 0.874432965  | 558.792432       | 1110.514825          |
| 10.35  | 412.40     | 2.079      | 0.283        | 73.5066402  | -0.964629165 | 242.6384268      | -827.0536375         |
| 10.36  | 411.10     | 1.965      | 0.216        | 77.52579829 | 0.848962046  | 174.487284       | 685.8013039          |
| 10.37  | 410.20     | 1.945      | 0.218        | 77.40840952 | 0.905011527  | 173.928802       | 722.0534917          |
| 10.38  | 409.70     | 1.931      | 0.218        | 77.40840952 | 0.905011527  | 172.4664926      | 715.9824029          |
| 10.39  | 412.70     | 1.984      | 0.216        | 77.52579829 | 0.848962046  | 176.8601088      | 695.1274066          |
| 10.40  | 412.90     | 1.99       | 0.22         | 77.29096701 | 0.948621161  | 180.76762        | 779.4544976          |
| 10.41  | 412.70     | 5.03       | 0.358        | 69.02258012 | -0.092326581 | 743.165398       | -191.6589946         |
| 10.42  | 411.00     | 4.97       | 0.36         | 68.89980398 | -0.213576429 | 735.3612         | -436.2661636         |
| 10.43  | 411.20     | 3.006      | 0.451        | 63.19213897 | 0.352541789  | 557.4663072      | 435.7653422          |
| 10.44  | 410.60     | 3.374      | 0.543        | 57.11190369 | 0.533925066  | 752.2528692      | 739.6807789          |
| 10.45  | 411.30     | 5.314      | 0.406        | 66.04619252 | -0.072682651 | 887.3731692      | -158.8587063         |
| 10.46  | 410.50     | 6.231      | 0.567        | 55.45870954 | -0.886607592 | 1450.287059      | -2267.787509         |
| 10.47  | 409.50     | 8.389      | 0.679        | 47.23445115 | -0.110336235 | 2332.565643      | -379.0375702         |
| 10.48  | 408.10     | 10.9       | 0.734        | 42.77721518 | -0.933868534 | 3265.04486       | -4154.118061         |
| 10.49  | 405.80     | 13.37      | 0.771        | 39.5562269  | 0.959290046  | 4183.095966      | 5204.672273          |
| 10.50  | 407.70     | 5.098      | 0.614        | 52.12070561 | 0.959822648  | 1276.171124      | 1994.947799          |
| <b>Mean Power Factor</b>                       |            |            | 0.464727273  |             |              |                  |                      |
| <b>Energy Meter Readings: 147.8 to 148.8Wh</b> |            |            |              |             |              |                  |                      |
| Time   |            | 0.55 hours |              |             |              |                  |                      |
| Kw   |            | 1.8182     |              |             |              |                  |                      |
| Angle  |            | 62.3079    |              |             |              |                  |                      |
| Kvar   |            | 3.4643     |              |             |              |                  |                      |
| Improved Angle(PF=0.9)                         |            | 25.8419    |              |             |              |                  |                      |
| Improved Kvar                                  |            | 0.8806     |              |             |              |                  |                      |
| Capacitor Ratings Should be                    |            | 2.5837     |              |             |              |                  |                      |


**GRAPH 1**



**GRAPH 1 shows the relation between the time and the power factor which is taken on a mentioned date of 29.08.2018**


**GRAPH 3**





**GRAPH 3** shows the relation between the time and the power factor which is taken on a mentioned date of 30.08.2018

**GRAPH 4**




**GRAPH 4** shows the relation between the Load Distribution in KW and KVAR which is taken on a mentioned date of 30.08.2018


**TABLE 3 READINGS TAKEN ON 31.08.2018**

| Time(am) | Voltage(V)                  | Current(A) | Power Factor                         | φ           | sinφ         | Active Power(KW) | Reactive Power(Kvar) |
|----------|-----------------------------|------------|--------------------------------------|-------------|--------------|------------------|----------------------|
| 2.29     | 405.6                       | 4.577      | 0.303                                | 72.3621205  | -0.105293924 | 562.4986536      | -195.4709263         |
| 2.30     | 405.2                       | 4.178      | 0.273                                | 74.15713739 | -0.946136267 | 462.1686888      | -1601.738307         |
| 2.31     | 406.1                       | 4.581      | 0.483                                | 61.11847925 | -0.989853036 | 898.5462003      | -1841.467255         |
| 2.32     | 405.1                       | 5.356      | 0.464                                | 62.35447705 | -0.459450131 | 1006.748038      | -996.8761171         |
| 2.33     | 406.3                       | 5.701      | 0.55                                 | 56.63298703 | 0.084219387  | 1273.973965      | 195.0787389          |
| 2.34     | 404.9                       | 6.514      | 0.59                                 | 53.8429918  | -0.422241541 | 1556.135974      | -1113.669918         |
| 2.35     | 406.4                       | 6.415      | 0.577                                | 54.76018593 | -0.976399926 | 1504.271312      | -2545.529285         |
| 2.36     | 406.1                       | 6.886      | 0.622                                | 51.53766738 | 0.955745927  | 1739.363661      | 2672.652307          |
| 2.37     | 405.8                       | 8.674      | 0.666                                | 48.24091153 | -0.898798871 | 2344.259527      | -3163.690416         |
| 2.38     | 406.7                       | 8.454      | 0.705                                | 45.17045595 | 0.927683094  | 2423.960469      | 3189.59879           |
| 2.39     | 405.5                       | 8.117      | 0.715                                | 44.35680084 | 0.365810662  | 2353.382103      | 1204.045125          |
| 2.40     | 409.1                       | 8.153      | 0.705                                | 45.17045595 | 0.927683094  | 2351.451572      | 3094.187048          |
| 2.41     | 412.5                       | 4.416      | 0.491                                | 60.59367011 | -0.785441853 | 894.4056         | -1430.76088          |
| 2.42     | 416.3                       | 4.469      | 0.469                                | 62.03059607 | -0.718231288 | 872.5485643      | -1336.229593         |
| 2.43     | 419.3                       | 4.53       | 0.493                                | 60.46204567 | -0.697415781 | 936.418497       | -1324.69176          |
| 2.44     | 415.4                       | 4.438      | 0.519                                | 58.73480265 | 0.816578067  | 956.799588       | 1505.398575          |
| 2.45     | 415.2                       | 4.875      | 0.574                                | 54.97036838 | -0.999971852 | 1161.8334        | -2024.043026         |
| 2.46     | 415.4                       | 5.345      | 0.582                                | 54.40866472 | -0.84232879  | 1292.22166       | -1870.233563         |
| 2.47     | 413.1                       | 5.15       | 0.644                                | 49.90925975 | -0.348736572 | 1370.08746       | -741.9248504         |
| 2.48     | 410.5                       | 4.67       | 0.708                                | 44.92757806 | 0.810661441  | 1357.26078       | 1554.066356          |
| 2.49     | 410.2                       | 5.476      | 0.691                                | 46.29068025 | 0.740093616  | 1552.162343      | 1662.439134          |
| 2.50     | 411.3                       | 5.643      | 0.694                                | 46.05241639 | 0.877906971  | 1610.750335      | 2037.592144          |
| 2.51     | 412                         | 7.121      | 0.737                                | 42.52351525 | -0.993732941 | 2162.248924      | -2915.465377         |
| 2.52     | 411.1                       | 8.299      | 0.751                                | 41.32292462 | -0.463747277 | 2562.200894      | -1582.175351         |
| 2.53     | 411.9                       | 8.343      | 0.717                                | 44.1926529  | 0.20880782   | 2463.957379      | 717.5642337          |
| 2.54     | 415                         | 2.194      | 0.28                                 | 73.73979529 | -0.996162767 | 254.9428         | -907.0161609         |
| 2.55     | 413.9                       | 2.221      | 0.249                                | 75.58165476 | 0.182404157  | 228.8987031      | 167.6790157          |
| 2.56     | 415.7                       | 2.205      | 0.285                                | 73.44115141 | -0.926318485 | 261.2362725      | -849.0806605         |
| 2.57     | 415.8                       | 3.347      | 0.448                                | 63.38456174 | 0.524994519  | 623.4738048      | 730.6257366          |
| 2.58     | 416                         | 6.71       | 0.676                                | 47.46814583 | -0.337496448 | 1886.95936       | -942.0740859         |
| 2.59     | 416.4                       | 8.065      | 0.685                                | 46.76439285 | 0.351803388  | 2300.41221       | 1181.449358          |
| 3.00     | 418.8                       | 1.952      | 0.167                                | 80.38656171 | -0.962167054 | 136.520992       | -786.5692576         |
| 3.01     | 418.4                       | 1.859      | 0.228                                | 76.82064807 | 0.989013062  | 177.3396768      | 769.2598977          |
| 3.02     | 418.2                       | 3.767      | 0.468                                | 62.09544966 | -0.671627587 | 737.2681992      | -1058.054832         |
| 3.03     | 418.2                       | 3.797      | 0.495                                | 60.33024966 | -0.597186814 | 786.013173       | -948.2761672         |
| 3.04     | 417.2                       | 8.358      | 0.667                                | 48.16405653 | -0.862488613 | 2325.800719      | -3007.461224         |
| 3.05     | 418.1                       | 1.821      | 0.166                                | 80.44466858 | -0.944720275 | 126.3857766      | -719.2723232         |
| 3.11     | 415.3                       | 6.58       | 0.715                                | 44.35680084 | 0.365810662  | 1953.86191       | 999.6412847          |
| 3.12     | 414.1                       | 9.369      | 0.737                                | 42.52351525 | -0.993732941 | 2859.341037      | -3855.388574         |
|          |                             |            |                                      |             |              |                  |                      |
|          |                             |            | Mean Power Factor                    | 0.538179487 |              |                  |                      |
|          |                             |            |                                      |             |              |                  |                      |
|          |                             |            | Energy Meter Reading: 151.7 to 153.3 |             |              |                  |                      |
|          |                             |            |                                      |             |              |                  |                      |
|          | Time                        |            | 0.7169 hours                         |             |              |                  |                      |
|          | Kw                          |            | 2.2318                               |             |              |                  |                      |
|          | Angle                       |            | 57.4388                              |             |              |                  |                      |
|          | Kvar                        |            | 3.495                                |             |              |                  |                      |
|          | Improved Angle(PF=0.9)      |            | 25.8419                              |             |              |                  |                      |
|          | Improved Kvar               |            | 1.0809                               |             |              |                  |                      |
|          | Capacitor Ratings Should be |            | 2.4141                               |             |              |                  |                      |

**GRAPH 5**



**GRAPH 5 shows the relation between the time and the power factor which is taken on a mentioned date of 31.08.2018**  
**GRAPH 6**




**GRAPH 6 shows the relation between the Load Distribution in KW and KVAR which is taken on a mentioned date of 31.08.2018**

**TABLE 4 READINGS TAKEN ON 05.09.2018**


| Time(am)                                       | Voltage(V) | Current(A)        | Power Factor | φ           | sinφ         | Active Power(KW) | Reactive Power(Kvar) |
|--|------------|-------------------|--------------|-------------|--------------|------------------|----------------------|
| 10.26  | 403.1      | 3.017             | 0.493        | 60.46204567 | -0.697415781 | 599.5632811      | -848.1640852         |
| 10.27  | 401.8      | 3.115             | 0.506        | 59.60224289 | 0.08790393   | 633.313142       | 110.0211743          |
| 10.28  | 401.9      | 3.108             | 0.505        | 59.66864764 | 0.021611099  | 630.798126       | 26.99452604          |
| 10.29  | 401.2      | 3.098             | 0.507        | 59.53579295 | 0.153853926  | 630.1592232      | 191.2277519          |
| 10.30  | 401.1      | 3.272             | 0.528        | 58.12957778 | 0.999948857  | 692.9467776      | 1312.33208           |
| 10.31  | 400.7      | 3.31              | 0.541        | 57.24826085 | 0.643906405  | 717.537497       | 854.0240109          |
| 10.32  | 400.9      | 3.284             | 0.547        | 56.83855713 | 0.285846205  | 720.1559132      | 376.3324223          |
| 10.38  | 400.6      | 80527             | 0.659        | 48.77634837 | -0.996667492 | 21258757.58      | -32151612.44         |
| 10.39  | 401.2      | 3.184             | 0.513        | 59.13613434 | 0.526200352  | 655.3168704      | 672.1792751          |
| 10.40  | 400.4      | 4.034             | 0.581        | 54.47909191 | -0.878167034 | 938.4391016      | -1418.427337         |
| 10.41  | 399.6      | 4.101             | 0.61         | 52.41049704 | 0.839617188  | 999.643356       | 1375.930728          |
| 10.42  | 399.5      | 4.255             | 0.621        | 51.6108034  | 0.974687936  | 1055.620823      | 1656.845218          |
| 10.43  | 399.2      | 4.356             | 0.622        | 51.53766738 | 0.955745927  | 1081.605254      | 1661.96112           |
| 10.44  | 398.3      | 4.492             | 0.63         | 50.94987746 | 0.632204377  | 1127.173068      | 1131.117059          |
| 10.45  | 399.8      | 4.105             | 0.502        | 59.86759262 | -0.17640424  | 823.871858       | -289.5109338         |
| 10.52  | 402        | 4.076             | 0.279        | 73.79946934 | -0.9996092   | 457.156008       | -1637.911654         |
| 10.53  | 102.9      | 4.114             | 0.281        | 73.68010311 | -0.989167397 | 118.9558986      | -418.7448276         |
| 10.54  | 401        | 5.144             | 0.4          | 66.42182152 | -0.433502452 | 825.0976         | -894.204581          |
| 10.55  | 400.4      | 5.077             | 0.386        | 67.29416448 | -0.968893226 | 784.6726888      | -1969.595992         |
| 10.56  | 399.7      | 40198             | 0.272        | 74.21668677 | -0.925190369 | 4370262.243      | -14865163.75         |
| 10.57  | 399.2      | 4.04              | 0.27         | 74.33573315 | -0.87357033  | 435.44736        | -1408.866274         |
| 10.58  | 398.7      | 4.204             | 0.444        | 63.64062321 | 0.723438639  | 744.2038512      | 1212.580678          |
| 10.59  | 399.9      | 6.14              | 0.615        | 52.04807971 | 0.977653908  | 1510.06239       | 2400.517718          |
| 11.00  | 399.3      | 7.128             | 0.691        | 46.29068025 | 0.740093616  | 1966.731386      | 2106.462148          |
| 11.01  | 398.4      | 7.465             | 0.717        | 44.1926529  | 0.20880782   | 2132.398152      | 621.0061511          |
| 11.02  | 397.3      | 8.791             | 0.626        | 51.24437751 | 0.829881382  | 2186.407852      | 2898.497078          |
| 11.03  | 398.2      | 5.503             | 0.677        | 47.39034507 | -0.263313459 | 1483.506444      | -576.9973602         |
| 11.04  | 397.7      | 6.597             | 0.71         | 44.76508467 | 0.705258371  | 1862.775099      | 1850.334833          |
| 11.05  | 397        | 8.674             | 0.752        | 41.23607767 | -0.385152604 | 2589.570656      | -1326.303033         |
|  |            |                   |              |             |              |                  |                      |
|  |            |                   |              |             |              |                  |                      |
|  |            | Mean Power Factor | 0.533965517  |             |              |                  |                      |
|  |            |                   |              |             |              |                  |                      |
| <b>Energy Meter Reading: 167.5 to 168.7 Wh</b> |            |                   |              |             |              |                  |                      |
|  |            |                   |              |             |              |                  |                      |
| Time   |            | 0.65 hours        |              |             |              |                  |                      |
| Kw   |            | 1.8462            |              |             |              |                  |                      |
| Angle  |            | 57.7239           |              |             |              |                  |                      |
| Kvar   |            | 2.9231            |              |             |              |                  |                      |
| Improved Angle(PF=0.9)                         |            | 25.8419           |              |             |              |                  |                      |
| Improved Kvar                                  |            | 0.8942            |              |             |              |                  |                      |
| Capacitor Ratings Should be                    |            | 2.0289            |              |             |              |                  |                      |

**GRAPH 7**



**GRAPH 7 shows the relation between the time and the power factor which is taken on a mentioned date of 05.09.2018**

**GRAPH 8**




**GRAPH 8 shows the relation between the Load Distribution in KW and KVAR which is taken on a mentioned date of 05.09.2018**

**TABLE 5 READINGS TAKEN ON 06.09.2018**


| Time(am)                                      | Voltage(V) | Current(A) | Power Factor             | $\phi$      | sin $\phi$   | Active Power(KW) | Reactive Power(Kvar) |
|---|------------|------------|--------------------------|-------------|--------------|------------------|----------------------|
| 10.18   | 407.4      | 3.296      | 0.451                    | 63.19213897 | 0.352541789  | 605.5984704      | 473.38973            |
| 10.19   | 407.5      | 3.23       | 0.452                    | 63.12792554 | 0.291765826  | 594.9337         | 384.0294745          |
| 10.20   | 406        | 3.31       | 0.471                    | 61.9007717  | -0.80226595  | 632.95806        | -1078.13312          |
| 10.21   | 405.9      | 3.423      | 0.502                    | 59.86759262 | -0.17640424  | 697.4766414      | -245.0952922         |
| 10.22   | 405.1      | 3.547      | 0.514                    | 59.06936301 | 0.58176531   | 738.5613058      | 835.9325821          |
| 10.23   | 407.7      | 3.877      | 0.521                    | 58.60064655 | 0.886448269  | 823.5201609      | 1401.167027          |
| 10.24   | 406.5      | 3.89       | 0.535                    | 57.65608859 | 0.894548847  | 845.987475       | 1414.536673          |
| 10.25   | 405.3      | 4.205      | 0.58                     | 54.54945736 | -0.909625731 | 988.48617        | -1550.262854         |
| 10.31   | 404.3      | 3.298      | 0.499                    | 60.06613744 | -0.367088467 | 665.3573186      | -489.468934          |
| 10.32   | 404.5      | 3.819      | 0.541                    | 57.24826085 | 0.643906405  | 835.7289555      | 994.697273           |
| 10.33   | 403.4      | 3.767      | 0.548                    | 56.77008748 | 0.219614902  | 832.7450744      | 333.7285178          |
| 10.34   | 403.7      | 3.761      | 0.552                    | 56.49567019 | -0.052972767 | 838.1102664      | -80.42938416         |
| 10.35   | 404        | 3.784      | 0.626                    | 51.24437751 | 0.829881382  | 956.988736       | 1268.669545          |
| 10.36   | 402.9      | 5.035      | 0.717                    | 44.1926529  | 0.20880782   | 1454.507276      | 423.5878577          |
| 10.37   | 402.4      | 8.197      | 0.786                    | 38.18673915 | 0.468531057  | 2592.599621      | 1545.436948          |
| 10.38   | 402.8      | 12.82      | 0.511                    | 59.26953778 | 0.408420181  | 2638.750856      | 2109.039337          |
| 10.39   | 404        | 3.369      | 0.529                    | 58.06208627 | 0.998354345  | 720.009204       | 1358.836138          |
| 10.40   | 408        | 3.489      | 0.493                    | 60.46204567 | -0.697415781 | 701.791416       | -992.7797334         |
| 10.41   | 408        | 3.52       | 0.517                    | 58.86876829 | 0.732162976  | 742.49472        | 1051.50318           |
| 10.42   | 408.3      | 4.557      | 0.583                    | 54.33817552 | -0.802277315 | 1084.743267      | -1492.735704         |
| 10.43   | 406.7      | 4.548      | 0.59                     | 53.8429918  | -0.422241541 | 1091.306244      | -781.0081868         |
| 10.44   | 406.4      | 4.717      | 0.593                    | 53.62981242 | -0.220900136 | 1136.774358      | -423.4630871         |
| 10.45   | 405.8      | 4.837      | 0.606                    | 52.6991645  | 0.650247838  | 1189.489888      | 1276.34196           |
|   |            |            | <b>Mean Power Factor</b> | 0.552913043 |              |                  |                      |
| <b>Energy Meter Reading: 171.1 to 171.8Wh</b> |            |            |                          |             |              |                  |                      |
|   |            |            |                          |             |              |                  |                      |
| Time  | 0.45 hours |            |                          |             |              |                  |                      |
| Kw  | 1.5556     |            |                          |             |              |                  |                      |
| Angle   | 56.4338    |            |                          |             |              |                  |                      |
| Kvar  | 2.3444     |            |                          |             |              |                  |                      |
| Improved Angle(PF=0.9)                        | 25.8419    |            |                          |             |              |                  |                      |
| Improved Kvar                                 | 0.7534     |            |                          |             |              |                  |                      |
| Capacitor Ratings Should be                   | 1.591      |            |                          |             |              |                  |                      |

**GRAPH 9**



**GRAPH 9 shows the relation between the time and the power factor which is taken on a mentioned date of 06.09.2018**

GRAPH 10



GRAPH 10 shows the relation between the Load Distribution in KW and KVAR which is taken on a mentioned date of 06.09.2018

ELECTRICAL BLUE PRINT

| Machines             | V(V) | I(A) | P(KW) | Quantity |
|----------------------|------|------|-------|----------|
| DC Motor             | 220  | 6.5  | 1.1   | 12       |
| 3φ Induction Motor   | 415  | 2.2  | 1     | 6        |
| AC Generator         | 415  | 2.8  | 1.2   | 6        |
| 1φ Induction Motor   | 230  | 7.6  | 1.1   | 5        |
| 3φ Induction Motor   | 415  | 3.15 | 1.1   | 5        |
| DC Motor             | 220  | 6.5  | 1.1   | 10       |
| DC Series Motor      | 220  | 6.8  | 1.5   | 1        |
| DC Shunt Motor       | 220  | 27.5 | 5.2   | 1        |
| AC Generator         | 415  | 7    | 4     | 1        |
| 3φ Synchronous Motor | 415  | 8.5  | 3.7   | 1        |
| DC Generator         | 220  | 15   | 3.5   | 1        |
| Induction Generator  | 415  | 7.5  | 3.7   | 1        |
| DC Motor             | 220  | 10   | 2.2   | 1        |
| DC Generator         | 220  | 10   | 2.2   | 1        |
| DC Motor             | 220  | 18.5 | 3.5   | 1        |
| DC Motor             | 220  | 19.6 | 3.7   | 1        |
| DC Generator         | 220  | 16.8 | 3.7   | 1        |
| AC Generator         | 415  | 8.5  | 3.7   | 1        |
| 3φ Synchronous Motor | 220  | 17   | 3.7   | 1        |
| DC Shunt Motor       | 220  | 27.5 | 5.2   | 1        |
| 3φ Alternator        | 415  | 7    | 5     | 1        |
| 3φ Induction Motor   | 415  | 5.2  | 2.2   | 1        |

10. RESULTS AND DISCUSSION

|      | Capacitance Required |
|------|----------------------|
|      | 3.6221               |
|      | 2.5837               |
|      | 2.4141               |
|      | 2.0289               |
|      | 1.591                |
| Mean | 2.44796              |

Thus, we have calculated the amount of Capacitor bank that has to be implemented in the lab so has to decrease the reactive power generated. This will in turn reduce the electricity bill for our Institution. We have also plotted various graphs for understanding purpose. Graph 1, Graph 3, Graph 5, Graph 7 and Graph 9 shows the relation between the time and the power factor for five different days. Graph 2, Graph 4, Graph 6, Graph 8 and Graph 10 shows the relation between the Load Distribution in KW and KVAR for five different days.

The Maximum power Demand of the lab is 69. 5855KW.The load on an installation is 2.232KW, 0.5 lagging p.f. which works for 1 hour per day. The energy consumed is 1. 6KWH.It has a reactive power of 3.495 KVAR. If we connect a capacitor of capacitance of 2.45KVAR is added. The Tariff of Tamil Nadu Government is given below

| For Handlooms in residence. 0 to 200 units bi-monthly is free. (Above 200 units bi-monthly, the corresponding slab in the domestic tariff is applicable) |  |                 |             |        |
|--|--|-----------------|-------------|--------|
| *I-B   | Huts in village panchayats,TAHDCO- Till installation of meters (Fully subsidized by the Govt.)   | 0               | 290/service | 0      |
|  | On installation of meters (Fully subsidized by the Govt.)  | 4.95            | 0           | 0      |
| I-C  | L.T. Bulk supply to residential Colonies of Railway, Defence, Police quarters etc.   | 4.60            | 120/service | 4.60   |
| II-A   | Public lighting by Govt./Local bodies, Public water supply, Sewerage etc.,   | 6.35            | 120/kW      | 6.35   |
| II-B(1)  | Govt and Govt. aided Educational Institutions, Govt. Hospitals and Research labs, etc.   | 5.75            | 120/kW      | 5.75   |
| II-B(2)  | Private Educational Institutions & Hostels   | 7.50            | 120/kW      | 7.50   |
| #II-C  | Actual Places of Public worship(Bi-monthly)  | 0-120 units     | 5.75        | 120/kW |
|  |  | Above 120 units | 5.75        | 120/kW |
| III-A(1)   | Cottage and Tiny Industries, Agricultural and allied activities, Sericulture, Floriculture, Horticulture and Fish/Prawn culture etc. (contracted load shall not exceed 12 kW) (Bi-monthly) |                 |             |        |



**Calculation****Before adding the capacitor**

Maximum Apparent Power Demand=  $69.5855/0.5=139.171\text{KVA}$   
 Apparent Power= $\text{SQRT}(\text{Active power}^2+\text{Reactive Power}^2)$   
 Apparent Power = 4.15 KVA  
 Total Cost =  $(5.75 \times 139.171) + (1.6 \times 120) = \text{Rs.}992.23/\text{day}$

**After adding the capacitor**

Reactive Power=1.045 KVAR  
 Active Power =  $\text{SQRT}(\text{Apparent Power}^2-\text{Reactive Power}^2)$   
 Active Power= 4.106KW  
 Energy Consumed=4.106 KWH  
 $\Phi=14.7439$   
 Improved Power factor=0.967  
 Maximum Apparent Power Demand=  $69.5855/0.967=71.9601\text{KVA}$   
 Total Cost =  $(5.75 \times 71.9601) + (4.106 \times 120) = \text{Rs.}906.49/\text{day}$

Saving Percentage =8.64%

[7]. Ms.ShardhaChandrakantDeshmukh, Ms.Varsha Arjun PatilEnergy Conservation and Audit. 2013

**11. CONCLUSION**

The electrical power required to drive a motor has three components: reactive power ( $P_r$ , kVAR), active power ( $P_a$ , kW), and apparent power ( $P_{ap}$ , kVA). The active power is the actual amount of work done by the motor and measured for billing purposes. The reactive power is the power required to magnetize the motor winding or to create magnetic flux, and is not recordable. The apparent power is the vector sum of kilowatts and KVAR and is the total amount of energy furnished by the utility company. Capacitor should not be selected as a means of correcting poor power factors that are the result of oversized motors or unbalanced pumping units. Choosing a capacitor for this purpose might cause overcorrection, which can result in a leading power factor. A leading power factor, in turn, might cause over voltages that would cause control-component failure or power-cable failure. This potential problem generally is avoided by connecting the capacitors downstream of the motor contactors and switching them on and off, along with the motor contactors. From our studies and analysis in machines lab using the energy auditing techniques we are recommending the capacitor of **2.44796 KVAR** for the machine's lab. The Maximum power Demand of the lab is 69.5855KW. The cost which is spent before adding the capacitor is Rs.992.23/day. The cost which is spent after adding the capacitor is Rs.906.49/day. Thus, the percentage of Savings is 8.64%. We have also plotted the load curve for each individual day.

**12. REFERENCE**

- [1]. Parash Goyal, B.Siva Kumar, K.Sudhakar Energy Audit: A Case Study of Energy Center And Hostel of MANIT, Bhopal. IEEE 2013
- [2]. Dr.K.Umesh, Miste.Mieeee (Madras Section), Energy Audit Report On a Technical Institute, (IOSR-JEEE) Volume 4, Issue 1 (Jan.Feb.2013), PP 23-37
- [3]. Malkait Singh, Gurpreet Singh, Harmandeep Singh, Energy Audit: a case Study to reduce lighting cost, AJCSIT, 2012
- [4]. Utilization of Electrical Power by R.K.Rajput New age international publishers
- [5]. Utilization of Electrical Power by N.V.Surya Narayana.New age international publishers
- [6]. Ashok S. and Rangan Banerjee, "An Optimization Mode for Industrial Load and Management", IEEE Transactions on Power Systems Vol.16, No.4, Nov.2007.[7]